



MacAllister Machinery Company, Inc.
7515 East 30th Street
P.O. Box 1941
Indianapolis, Indiana 46206
(317) 540-2101

LOAD BANK TEST REPORT

CUSTOMER: USED EQUIP **SITE:** HQ YARD **Job#**

Pre-Start up Checks:

<u> X </u> 1. Eng. Oil Level	<u> X </u> 4. Safety ground connected
<u> X </u> 2. Coolant Level	<u> X </u> 5. Circuit breaker open (off)
<u> X </u> 3. Generator and load bank connected for proper volts	

Test Date: 10/02/25
Tested By: 1363
Title: tech
Tested At: 100%
Ambient Temp: 58

Engine Model:	C32	Serial Number:	SYC01283	KW:	1000
Generator Mfg/Mo	SR4B-GD	Serial Number:	G5D00282		
Control Panel Mfg:	Cat	Serial Number:	C32JSXC01409		

Engine Safeties - Operational Test and/or Set Points:

Low Oil Pressure:	<u>30</u>	PSI	Overspeed:	<u>2120</u>	RPM:	<u>1800</u>
Hi Water Temp:	<u>225</u>	°F	Hours Before:	<u>431</u>	Hours After:	<u>433</u>

Test Load/Duration: _____ **Min. Record Inter** _____

[illegible]

Customer Witness Acceptance:

MacAllister Engine Power Approval:

By: _____

Title: _____

By: _____

Title: TECH _____

OTHER PRODUCTS

VO-1054536

vals[illegible]