

LOAD BANK TEST REPORT

Pre-Start up Checks:

Test Date: 12/01/25

Tested By: 1363

Title: tech

Tested At: 100%%

Ambient Temp: 30

Serial Number: T3300923

KW: 500

Serial Number: **G6B25810**

Serial Number:

Low Oil Pressure: **30** PSI

Overspeed: 2120

RPM: 1800

Hi Water Temp: 225 F

Hours Before: 100

Hours After: 101

Test Load/Duration: 1.0 Hr

Min. Record Intervals

[illegible]

Customer Witness Acceptance:

MacAllister Engine Power Approval:

By: _____

By: _____

Title: _____

Title: TECH _____

